

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Ex. Mohit kumar (A.E.)

(Name of Officers with designation) from Uttar Pradesh, Jal Nigam PHED

inspected the W WINGS SCHOOL Rohta Agra

(Name & Address of the school) on 28/03/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. UPDN/AYR/25/03/213 dated 28/03/2025

of Regional water testing laboratory PHED Lab) certified that


the W wings school Rohta Agra (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 06

  
28/3/25

Signature with Seal: .....  
Name : Ex. Mohit kumar  
Designation : Assistant Eng  
Name & Address of the Office / Department: .....

To The Manager  
W WINGS SCHOOL Rohta, Agra  
(Name & Address of the Institution)

Analyst (Chemist)

Note: The certificate is to be issued by authorized officer / PHED lab / local bodies

W WINGS SCHOOL



CHAIRMAN

67 | Page

Deepa Dixit  
PRINCIPAL  
W WINGS SCHOOL  
Bamroll Road, Rohta, Agra



**Analysis Report**  
**Regional Water Testing Laboratory**  
Address :4/4 Sanjay Palace U.P. Jal Nigam,(Rural) Agra, 282002

Report No.	160	Issue Date:	28/03/2025	Page No	1
Contact Person:	Sanjay Upman	Address:	Ex En Up Jal Nigam Division Office Agra	Mob:	9761093634

**Customer Details**

Office Name and Address	W Wings School Silver Gold Colony, Bamroli Road, Rohta Agra
Ref Letter No & Date	21/03/2025

**Basic details of sample**

District	Agra	Block	Barauli Ahir
Gram Panchayat	Nainana Jat	Village/City	Silver Gold Colony
Habitation		Location	W Wings School (Fostering Quality Education)
Water Source	R.O. water	Sample No.	01
Quantity of Sample	1 L	Date of Collection	21/03/2025
Receiving Date	21/03/2025	S. Collector	Mr.Om Singh
Sample Depositor	Mr.Om Singh	Sampling Method	ISO 19458:2006(E)
Analysis Start Date	22/03/2025	Analysis Completion Date:	23/03/2025

**Technical Data of Analysis**

S.No.	Analyzed parameters	Unit of Measurement	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2		3	4	5	6
1	pH	-	7.89	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Total Coliform	CFU/100 ml	00	No Relaxation	No Relaxation	APHA 23 Edition:2017
3	E.Coli	CFU/100 ml	00	No Relaxation	No Relaxation	APHA 23 Edition:2017

**Note**

1. This Certificate refers only to the particular sample(s) submitted for testing.
- 2 This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
- 3The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
- 4 Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports.
- 5 TNTC :- Too Numerous to Count

  
Aditya Kumar Singh


(TMI / Microbiologist)

**W WINGS SCHOOL**



**CHAIRMAN**

  
**PRINCIPAL**  
**W WINGS SCHOOL**  
Bamroli Road, Rohta, Agra

  
Sanjay Upman

( Authorized Signatory )  
Testing Lab Incharge/QM

-----End Of Report-----



# Regional Water Testing Laboratory

Address: 4/4 Sanjay Palace U.P. Jal Nigam(Rural) Agra, 282002



## TEST REPORT

Report No:	UPJN/AGR/25/03/263	Issue Date:	28/03/2025	Page No	1/2
Customer Details					
Office Name and Address	W Wings School Silver Gold Colony, Bamroli Road, Rohta Agra				
Ref Letter No & Date	21/03/2025				
Basic details of sample					
District	Agra	Block	Barauli Ahir		
		Village/city	Silver Gold Colony		
Gram Panchayat	Nainana Jat	Location	W Wings School (Fostering Quality Education)		
Water Source	R.O. Water	Sample No.	01		
Quantity of Sample	1 Lt.	Date of Collection	21/03/2025		
Receiving Date	21/03/2025	S. Collector	Mr. OM Singh		
Sample Depositor	Mr. OM Singh	Sampling Method	As per IS 17614: Part 1: 2021		
Analysis Start Date	22/03/2025	Analysis Completion Date:	27/03/2025		
Humidity	55%	Temperature	27°C		

### Technical Data of Analysis

S.No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS, 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH (@ 25°C)	7.89	6-8.5	6.5-8.5	IS 3025 (Part 11):2022 ( Electrometric method)
2	Turbidity mg/L	0.68	1	5	IS 3025 (Pt 10):2023 (Nephelometric Method)
3	Total Dissolved Solid mg/L	96.4	500	2000	IS 3025 (Pt 16):2023 (Gravimetric Method)
4	Fluoride mg/L	1.22	1	1.5	APHA 24 <sup>th</sup> Edition 4500-F Method C (Electrode method) 2023
5	Total Hardness mg/L	28	200	600	IS 3025 (Part 21):2009(EDTA Method)
6	Total Alkalinity mg/L	42	200	600	IS 3025 (Part 23):2023 (Potentiometric method)

1

Report No: UPJN/AGR/25/03/263

W WINGS SCHOOL


CHAIRMAN

*Sanjay Dixit*  
PRINCIPAL  
W WINGS SCHOOL  
Bamroli Road, Rohta, Agra



## Regional Water Testing Laboratory

Address: 4/4 Sanjay Palace U.P. Jal Nigam(Rural) Agra, 282002



7	Chloride mg/L	18	250	1000	IS 3025 (Part 32):1988(Argentometric method)
8	Iron mg/L	0.01	1	1	APHA 24 <sup>th</sup> Edition 3500-Fe Method B (Phenanthroline Method) 2023
9	Sulphate mg/L	2	200	400	APHA 24 <sup>th</sup> Edition 4500-SO4 Method E (Turbidimetric Method) 2023
10	Calcium mg/L	18	75	200	IS 3025 (Part- 40):2024(EDTA Titrimetric Method)
11	Magnesium mg/L	4.32	30	100	IS 3025 (Part 46):2023(Volumetric Method)
12	Color (Hazen)	-	5	15	IS 3025 (Part 4) ,2021 Visual Comparison Method
13	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (PART 08) ,2023 (Qualitative Method)
14	Nitrate (mg/l)	Nil	45	45	APHA 24 <sup>th</sup> Edition -4500 NO3 method D (UV Screening Method)


Note :

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports.

Reviewed By-

  
(Amita Devi )

(Deputy Quality Manager)

  
Authorized Signatory  
(Sanjay Upman)


Laboratory Contact details  
Email- ZlaupjnR@gmail.com  
Mob. (8630905287)

2

Report No: UPJN/AGR/25/03/263

W WINGS SCHOOL

  
CHAIRMAN

  
PRINCIPAL  
W WINGS SCHOOL  
Bamroll Road, Rohta, Agra



National Accreditation Board for  
Testing and Calibration Laboratories

NABL

**CERTIFICATE OF ACCREDITATION**

**REGIONAL WATER TESTING LABORATORY, U.P JAL  
NIGAM (RURAL)**

has been assessed and accredited in accordance with the standard

**ISO/IEC 17025:2017**

**"General Requirements for the Competence of Testing &  
Calibration Laboratories"**

for its facilities at

4/4 SANJAY PALACE, AGRA, UTTAR PRADESH, INDIA

in the field of

**TESTING**

Certificate Number: TC-13228

Issue Date: 09/03/2024

Valid Until:

08/03/2026

This certificate remains valid for the Scope of Accreditation as specified in the annexure subject to continued satisfactory compliance to the above standard & the relevant requirements of NABL.  
(To see the scope of accreditation of this laboratory, you may also visit NABL website [www.nabl-india.org](http://www.nabl-india.org))

Name of Legal Entity: Uttar Pradesh Jal Nigam (RURAL)

Signed for and on behalf of NABL



N. Venkateswaran  
Chief Executive Officer

W WINGS SCHOOL

  
CHAIRMAN  
PRINCIPAL  
W WINGS SCHOOL  
Bamroll Road, Rohta, Agra



NABL

# National Accreditation Board for Testing and Calibration Laboratories

## SCOPE OF ACCREDITATION

Laboratory Name :

REGIONAL WATER TESTING LABORATORY, U.P JAL NIGAM (RURAL), 4/4 SANJAY PALACE  
AGRA, UTTAR PRADESH, INDIA

Accreditation Standard

ISO/IEC 17025:2017

Certificate Number

TC-13228

Validity

09/03/2024 to 08/03/2026

Page No

1 of 1

Last Amended on

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
Permanent Facility				
1	CHEMICAL- WATER	Drinking Water	Calcium (as Ca)	IS 3025 (Part 40)
2	CHEMICAL- WATER	Drinking Water	Chloride (as Cl)	IS 3025 (Part 32)
3	CHEMICAL- WATER	Drinking Water	Colour	IS 3025 (part 4)
4	CHEMICAL- WATER	Drinking Water	Fluoride (as F)	APHA 24th Edition -4500-F Method C (Electrode Method)
5	CHEMICAL- WATER	Drinking Water	Iron (as Fe)	APHA 24th Edition -3500-Fe Method B (Phenanthroline Method)
6	CHEMICAL- WATER	Drinking Water	Magnesium (as Mg)	IS 3025 (Part 46)
7	CHEMICAL- WATER	Drinking Water	Nitrate (as NO <sub>3</sub> )	APHA 24th Edition NO <sub>3</sub> Method D (UV Screening Method)
8	CHEMICAL- WATER	Drinking Water	Odour	IS 3025 (Part 5)
9	CHEMICAL- WATER	Drinking Water	pH	IS 3025 (Part 11)
10	CHEMICAL- WATER	Drinking Water	Sulphate (as SO <sub>4</sub> )	APHA 24th Edition -4500-SO <sub>4</sub> Method E (Turbidimetric Method)
11	CHEMICAL- WATER	Drinking Water	Taste	IS 3025 (Part 8)
12	CHEMICAL- WATER	Drinking Water	Total Alkalinity (as CaCO <sub>3</sub> )	IS 3025 (Part 23)
13	CHEMICAL- WATER	Drinking Water	Total Dissolved Solids	IS 3025 (Part 16)
14	CHEMICAL- WATER	Drinking Water	Total Hardness (as CaCO <sub>3</sub> )	IS 3025 (Part 21)
15	CHEMICAL- WATER	Drinking Water	Turbidity	IS 3025 (Part 10)

W WINGS SCHOOL

CHAIRMAN

*Vinay Singh*  
PRINCIPAL  
W WINGS SCHOOL  
Bamroli Road, Rohta, Agra